Commercial Testing Lab

514 Main Street, PO Box 526
Colfax, WI 54730
715-962-3121
www.ctlcolfax.com

WDNR Laboratory ID Number: 617013980

WDATCP Lab Certification: #105-19

Village of Milltown
PO Box 485
Milltown, WI 54858

Order ID: 27643
Reporting Date: 08/12/2026
PWSID: 64903399

System Name: Milltown Waterworks
Sample Address: 201 Industrial Avenue, Milltown, WI 54858
Collected Date: 08/10/2026
Received by Lab: Date: 08/10/2026 Time: 01:10 PM
Sampler: M. Nutter

Analytical Results

Sample ID	Sample Source	Collected Time	Sample Qualifier	Parameter	Result	Unit	MCL	LOD	LOQ	Analytical Method	Analysis Date/Time
27643-1	Office Door Tap/D5	07:10 AM	-	E. Coli	Absent	NA	NA	N/A	N/A	SM9223B Colilert	08/10/2026 03:20 PM
27643-1	Office Door Tap/D5	07:10 AM	-	Total Coliform	Absent	NA	NA	N/A	N/A	SM9223B Colilert	08/10/2026 03:20 PM

Notes:

1. Bacteriological analysis of this sample indicates this water is **SAFE** for human consumption.
2. LOD/LOQ values adjusted for dilutions, solids content, or where non-typical sample volumes are used.
3. < Means "LESS THAN" Detectable Limit.
4. NA - Not Applicable.
5. ND - Not Detected

Reported by,

Z. Christianson

Z. Christianson, Micro Lab Supervisor